

**POWER GRID CORPORATION OF INDIA LIMITED**  
**EASTERN REGIONAL LOAD DESPATCH CENTER**  
**ATC of Eastern Region for the month of July, 2009**  
**JULY 1 to JULY 25**

**Export Capability**

Corridor	Time Period	Total Transfer Capability	Reliability Margin	Scheduling Limit	Long Term Open Access	Available Transfer Capability for STOA
ER - NR	00:00 – 17:00	2600	300	2300	1546	754
	23:00 – 24:00					
	17:00 – 23:00					
ER - WR	00:00 – 17:00	1700	500	1200	695	505
	23:00 – 24:00					
	17:00 – 23:00					
ER - SR	00:00 – 17:00	1595	50	1545	97	1448
	23:00 – 24:00					
	17:00 – 23:00					
ER - NER	00:00 – 17:00	400	100	300	157	143
	23:00 – 24:00					
	17:00 – 23:00					

**Import Capability**

Corridor	Time Period	Total Transfer Capability	Reliability Margin	Scheduling Limit	Long Term Open Access	Available Transfer Capability for STOA
NR - ER	00:00 – 17:00	400	100	300	0	300
	23:00 – 24:00					
	17:00 – 23:00					
WR - ER	00:00 – 17:00	500	100	400	0	400
	23:00 – 24:00					
	17:00 – 23:00					
SR - ER	00:00 – 17:00	700	50	650	186	464
	23:00 – 24:00					
	17:00 – 23:00					
NER - ER	00:00 – 17:00	300	100	200	0	200
	23:00 – 24:00					
	17:00 – 23:00					

**Note:** Revision on account of reduced Hydro availability from Tala, Orissa & NER  
One unit of TSTPP under Shutdown