

**POWER GRID CORPORATION OF INDIA LIMITED**  
**EASTERN REGIONAL LOAD DESPATCH CENTER**  
**ATC of Eastern Region for the month of September, 2009**

**Export Capability**

Corridor	Time Period	Total Transfer Capability	Reliability Margin	Scheduling Limit	Long Term Open Access	Available Transfer Capability for STOA
ER - NR	00:00 – 17:00	2800	300	2500	1512	988
	23:00 – 24:00					
	17:00 – 23:00					
ER - WR	00:00 – 17:00	1800	500	1300	672	628
	23:00 – 24:00					
	17:00 – 23:00					
ER - SR	00:00 – 17:00	1695	50	1645	-93	1738
	23:00 – 24:00					
	17:00 – 23:00					
ER - NER	00:00 – 17:00	500	100	400	154	246
	23:00 – 24:00					
	17:00 – 23:00					

**Import Capability**

Corridor	Time Period	Total Transfer Capability	Reliability Margin	Scheduling Limit	Long Term Open Access	Available Transfer Capability for STOA
NR - ER	00:00 – 17:00	350	100	250	0	250
	23:00 – 24:00					
	17:00 – 23:00					
WR - ER	00:00 – 17:00	500	100	400	0	400
	23:00 – 24:00					
	17:00 – 23:00					
SR - ER	00:00 – 17:00	650	50	600	93	507
	23:00 – 24:00					
	17:00 – 23:00					
NER - ER	00:00 – 17:00	300	100	200	0	200
	23:00 – 24:00					
	17:00 – 23:00					

**Note :**

- 1 **FSC at purnea in service**
- 2 (n-1) contingency of Purnea-Muzaffarpur line has been considered for arriving at ER-NR.
- 3 (n-1) contingency of Rourkela-Raigarh line has been considered for arriving at ER-WR TTC.
- 4 For exporting power to SR, capacity of Talcher-Kolar link has been considered as **2360 MW**.
- 5 (n-1) contingency of Talcher - Rourkella has been considered for arriving at SR - ER TTC under peak and off peak hours.
- 6 (n-1) contingency of Binaguri-Bongaigaon line has been considered for arriving at NER-ER TTC
- 7 Import TTC mentioned are not simultaneous capacity and depends on the flows on the other links

## NTPC availability considered for Sept-09

<b>FSTPP</b>	<b>1485</b>
<b>KHSTPP-I</b>	<b>565</b>
<b>KHSTPP-II</b>	<b>1395</b>
<b>TSTPP-I</b>	<b>465</b>
<b>TSTPP-II</b>	<b>1860</b>

Unit 7 has been considered

## Variation of hydro generation considered during peak and off-peak

<b>Station</b>	<b>Peak</b>	<b>Off-peak</b>
Teesta	510	510
Rangit	60	60
Chukha	320	320
Tala	1020	1020
Kurichu	60	60
Burla	200	200
Chiplima	25	25
Balimela	240	60
Rengali	250	250
U. Kolab	240	80
Indravati	600	300
Subarnarekha	120	120
Maithon	60	60
Panchet	80	80
PPSP	675	0
Rammam	50	50
TCF	60	60
Jaldhaka	0	0

Long term bilateral from DVC to NR and DVC to WR have been considered 200MW each.