

REJECTED APPLICATIONS

ERLDC NODAL

Sl No	Name of the customer	Acceptance for scheduling Number	Period of Open Access granted			Point of Injection	Point of Drawal	Transmission System used		Time Period		Capacity (MW)
			Date	From Date	To Date			State	Region	From	To	
1	NVVN	CC/NVVN/OA/2009-10/5340	15.04.2010	16.04.10	16.04.10	APDCL	WBSEDCL	-	WBSETCL	00:00	17:00	40
										23:00	24:00	40
Reason:	The outage of 400 KV Purnea - Binaguri I,II,III,IV;400 KV Purnea - Malda- I&II; 220 KV Dalkhola-Siliguri D/C ; 220 KV Malda-Dalkhola D/C;220 KV Purnea - Dalkhola D/C lines due to tower collapse.											